

2nd Floor

MTL #	MATERIAL DESCRIPTION	LOCATION	F/NF ¹	COND. ²	% ACM	# SAMP.	QUANTITY
25	White spray-on ceiling material	2078, 2064, 2032, 2002	F	Good	4%	9	11,400 SF
26	Blue carpet mastic	2078	NF	Good	ND	3	N/A
27	Black cove base/mastic	All rooms except 2106, 2070, 2042a, 2036, 2014, 2108	NF	Good	Cove base = ND Mastic = ND	3	N/A

