

California State University East Bay  
 Testing for Lead Levels in Drinking Water and Follow up Actions  
 (updated on 07/11/2018)

Phase I water samples from university drinking water sources were collected during the month of June by Intertek PSE Environmental Services and sent to a California certified laboratory for analysis. Test results are presented in the following table. The action level is set at the EPA's Maximum Contaminant Level (MCL) of 15 ppb (1 ug/liter = 1 ppb or part per billion). 4 A&E1

	st Fl.	Water fountain by MRR161	<5	No action required
5	A&E2 <sup>nd</sup> Fl.	Water fountain by Rm.260E	<5	No action required
6	A&E3 <sup>rd</sup> Fl.	Water fountain by Rm.360	<5	No action required
7	A&E3 <sup>rd</sup> Fl.	Sink faucet in Breakroom Rm.392	10	No action required
8	A&E1 <sup>st</sup> Fl.	Sink faucet in Breakroom Rm.193	9	No action required
122	A&E1 <sup>st</sup> Fl.	Water fountain (R) near Rms. 142/153	5	No action required
123	A&E1 <sup>st</sup> Fl.	Water fountain (L) near Rms. 142/153	<5	No action required
124	A&E1 <sup>st</sup> Fl.	Sink faucet (1) in Lab153	9	No action required

GB6 #c£11òF

Sample Number	Building and Floor	Sample Location	Lead Conc. (ppb)	Action
---------------	--------------------	-----------------	------------------	--------

22	MI 2 <sup>nd</sup> Fl.			
----	------------------------	--	--	--

Sample Number	Building and Floor	Sample Location	Lead Conc. (ppb)	Action
54B	KPE <sup>nd</sup> Fl.	Water fountain in Gym Rm. 202	< 5	No action required
55	KPE <sup>nd</sup> Fl.	Water fountain in Rm. 201A(R)	12	No action required
56	KPE <sup>nd</sup> Fl.	Water fountain in Rm. 201A(L)	7	No action required
57	KPE <sup>st</sup> Fl.	Sink		

Sample Number	Building and Floor	Sample Location	Lead Conc. (ppb)	Action
				service
84	Science 2 <sup>nd</sup> Fl.	Water fountain near Rm. S204	<5	No action required
85	Science 2 <sup>nd</sup> Fl.	Water fountain near Rm. S204	<5	No action required
86	Science 2 <sup>nd</sup> Fl.	Water fountain near Rm. S247	16	Removed

Sample Buildingand

Number

707 Tc18orj /TT3 1 Tf 2.990984 TD 0 Tc <0003>Tj ET /Cs6 cs .93333 .92549 .88235 scn 12297